CERTIFICATE OF APPROVAL No CF 252

This is to certify that, in accordance with TS00 General Requirements for Certification of Fire Protection Products The undermentioned products of

GEZE GmbH

Reinhold-Vöster-Straße 21 – 29 71229 Leonberg Germany 01543 443024 – 07702511350

Have been assessed against the requirements of the Technical Schedule(s) denoted below and are approved for use subject to the conditions appended hereto:

CERTIFIED PRODUCT

TECHNICAL SCHEDULE

TS2000 and TS4000 Series Overhead Door Closers

TS 34 - The Contribution Of Controlled Door Closing Devices And Accessories To Fire Resisting Doorsets

Signed and sealed for and on behalf of Warringtonfire Testing and Certification Limited

Paul Duggan Certification Manager

Issued: Revised: Valid to: 1st May 1997 11th December 2023 30th May 2028



Page 1 of 8

This certificate is the property of Warringtonfire Testing and Certification Limited

Registered in England and Wales

Registered Office: 3rd Floor, Davidson Building, 5 Southampton Street, London, WC2E 7HA. Company Registration No: 11371436

CERTIFICATE No CF 252 GEZE GmbH

TS2000 and TS4000 Series OVERHEAD DOOR CLOSERS

- 1. This certification is provided to the client for their own purposes, and we cannot opine on whether it will be accepted by Building Control authorities or any other third parties for any purpose.
- 2. This approval relates to Geze overhead mounted door closing devices and configurations as follows:

	Link-arms			Slide arms			
	Projecting arm (Fig. 1) Body door mounted on pull face	Projecting arm (Fig. 61) Body transom mounted on push face	Parallel arm (Fig. 6) Body door mounted on push face	Body door mounted on pull face	Body transom mounted on push face	Body door mounted on push face	Body transom mounted on pull face
TS2000 NV	✓	×	✓	×	×	×	×
TS2000 NV BC	√	×	✓	×	x	x	×
TS4000	✓	✓	×	×	×	×	×
TS4000 S	✓	✓	×	×	×	×	×
TS4000 E	✓	✓	✓	×	×	×	×
TS 4000 EFS	✓	✓	✓	×	×	×	×
TS4000 EN 5-7	✓	✓	×	×	×	×	×

Key: - approved

Not approved

Note: Where alternative arms for non-fire applications are included within the packaging, the use of these components on fire resisting door assemblies will invalidate the certification.

- 3. The closer is approved based on:
 - i) Initial type testing to EN1154 and BS EN 1634-1.
 - ii) An appraisal against TS34

fal ligg-

- iii) Inspection of quality management system
- iv) Inspection and surveillance of factory production control
- v) Ongoing audit testing in accordance with EN 1154 requirements

Signed J/078 & C/007

Page 2 of 7

Issued: 1st May 1997 Revised: 11th December 2023 Valid to: 30th May 2028

This certificate is the property of Warringtonfire Testing and Certification Limited Registered in England and Wales Registered Office: 3rd Floor, Davidson Building, 5 Southampton Street, London, WC2E 7HA. Company Registration No: 11371436

CERTIFICATE No CF 252 GEZE GmbH

TS2000 and TS4000 Series OVERHEAD DOOR CLOSERS

4. This approval relates to their use with the following door assemblies: -

Latched and unlatched, intumescent sealed door assemblies consisting of timber faced and edged leaves with timber or cellulosic cores in timber frames having a fire resistance up to 120 minutes (Code ITT).

Latched and unlatched, door assemblies consisting of predominantly steel faced and edged leaves in steel frames, <u>fully insulated</u> for the required classification period as defined by EN1634-1 or BS476-22, with or without intumescent sealing, and having a fire resistance up to 240 minutes (Codes MM & IMM)

Latched and unlatched, door assemblies consisting of predominantly steel faced and edged leaves in steel frames, <u>uninsulated</u> for the required classification period, with or without intumescent sealing, and having a fire resistance up to 240 minutes (Codes MM & IMM) <u>with closers fitted to the fire risk face only</u>*

Latched and unlatched, intumescent sealed door assemblies consisting of timber faced and edged leaves with timber, cellulosic or mineral cores in <u>fully insulated</u> steel frames as defined by EN1634-1 or BS476-22, having a fire resistance up to 120 minutes (Code ITM)

*The closer <u>must not be used</u> in this application where a specific direction of fire exposure for the doorset cannot be identified

- 5. This approval is applicable only to the specified closers when mounted in the applications stated later under the classification codes section of this certificate and used with door assemblies of proven fire resistance (as defined in BS EN 1634-1:2014+A1:2018 or BS 476-22: 1987.) and having power ratings appropriate to the leaf sizes subject to a minimum size 3 (as specified in BS EN 1154).
- 6. Where the closers are fitted to door leaves or frames that are manufactured from low-density cellulosic- based material, the door assembly shall have previously been shown capable of accommodating the installation of closers at the head of the doorset, without detriment to the door assembly's performance.
- 7. The closers shall be fixed with screws supplied by the closer manufacturer. Bolt-through fixings shall not be used.
- 8. Timber based doorset shall be installed in accordance with BS 8214.
- 9. The approval relates to on-going production. The product and/or its immediate packaging are identified with the manufacturer's name, the product name or number, the CERTIFIRE name or name and mark, together with the CERTIFIRE certificate number and application where appropriate.

Signed J/078 & C/007

fal kgg-

Page 3 of 7

Issued: 1st May 1997 Revised: 11th December 2023 Valid to: 30th May 2028

CERTIFICATE No CF 252 GEZE GmbH

TS2000 and TS4000 Series OVERHEAD DOOR CLOSERS

10. The following tables show acceptable doorset types and fire resistance periods:

	Approved Door Type				
Class	MM	IMM	ITT	ITM	
FD20	√ *#	√ *#	\checkmark	√*	
FD30	✓*#	√ *#	\checkmark	√*	
FD60	√ *#	√ *#	\checkmark	√*	
FD120	✓*#	√ *#	\checkmark	√*	
FD240	✓*#	√ *#	×	×	
E 20	√ #	√ #	\checkmark	√*	
EI 20	√*	√*	\checkmark	√*	
E 30	√ #	√ #	\checkmark	√*	
EI 30	√*	√*	\checkmark	√*	
E 60	√ #	√ #	\checkmark	√*	
EI 60	√*	√*	\checkmark	√*	
E 90	√#	√ #	\checkmark	√*	
EI 90	√*	√*	\checkmark	√*	
E 120	√#	√ #	\checkmark	√*	
EI 120	√*	√*	\checkmark	√*	
E 240	√#	√ #	×	×	
EI 240	√*	√*	×	×	

Key:

approved

l ligg

Not approved

- **Fully insulated** steel-based doors and frames only
- Fitted to the fire risk face only of Uninsulated steel-based doors and frames only
- Fitted to Fully insulated steel-based doors and frames, or the fire risk face only of Uninsulated steel-based doors and frames

Signed J/078 & C/007

Page 4 of 7

Issued: 1st May 1997 Revised: 11th December 2023 Valid to: 30th May 2028

Registered Office: 3rd Floor, Davidson Building, 5 Southampton Street, London, WC2E 7HA. Company Registration No: 11371436

CERTIFICATE No CF 252 GEZE GmbH

TS2000 and TS4000 Series OVERHEAD DOOR CLOSERS

11. Doors are classified as the following types:

Code ITT - 20 minute to 120 minute door assemblies door assemblies incorporating intumescent perimeter seals and consisting of timber faced and edged leaves with timber or cellulosic cores, hung in timber or cellulosic frames.

Code ITM - 20 minute to 120 minute door assemblies door assemblies incorporating intumescent perimeter seals and consisting of timber faced and edged leaves with timber or cellulosic cores, hung in steel frames

Code MM - 20 minute to 240 minute doorsets consisting of uninsulated or insulated predominantly steel leaves, hung in steel frames without intumescent seals.

Code IMM - 20 minute to 240 minute doorsets consisting of uninsulated or insulated predominantly steel leaves, hung in steel frames with intumescent seals

Limitations of Approval:

- Doors may not include uninsulated glass above 20% of their total area. Uninsulated glass shall not be included directly beneath the door closer body
- The closers may not be fitted to doorsets incorporating timber leaves without leaf/frame edge intumescent protection to the frame rebate or door edge.
- Closers are approved for use on both sides of steel-based doors and frames that are fully-insulated for the required classification period (insulation as defined by EN1634-1 or BS476-22).
- For uninsulated steel-based doors and frames the closers shall be fitted to the fire risk face only. The closer must not be used in this application where a specific direction of fire exposure for the doorset cannot be identified.
- Mechanical Hold open option is not approved.

Signed J/078 & C/007

Pl bgg-

Page 5 of 7

Issued: 1st May 1997 Revised: 11th December 2023 Valid to: 30th May 2028

CERTIFICATE No CF 252 GEZE GmbH

TS2000 and TS4000 Series OVERHEAD DOOR CLOSERS

Limitations of Approval – Cont'd:

The following functions are supported by this certification:

Closer Ref.	Latch Control	Backcheck	Delayed- Action
TS2000 NV	Yes	No	No
TS2000 NV BC	Yes	Yes	No
TS4000	Yes	Yes	No
TS4000 S	Yes	Yes	Yes
TS4000 E	Yes	No	No
TS 4000 EFS	Yes	No	No
TS4000 EN 5-7	Yes	Yes	No

Classification codes

This approval provides the following classifications for the closers as detailed:

For models TS2000 NV & TS2000 NV BC in projecting arm (Figure 1) and parallel arm (Figure 6) applications:

4 8	4 2	1	1	4
-----	--------	---	---	---

For model TS4000 in projecting arm (Figure 1) and transom mount (Figure 61) applications:

4	8	6	1	1	4

For model TS4000 S in projecting arm (Figure 1) and transom mount (Figure 61) applications:

4 8 6 1 1	4
-----------	---

For models TS4000 E & TS4000 EFS in projecting arm (Figure 1), parallel arm (Figure 6) and transom mount (Figure 61) applications to EN1154:

4 8 6 1	1	1	4
------------	---	---	---

Signed J/078 & C/007



Page 6 of 7

1st May 1997 11th December 2023 Revised: 30th May 2028

Issued:


Valid to:

CERTIFICATE No CF 252 GEZE GmbH


TS2000 and TS4000 Series OVERHEAD DOOR CLOSERS

Classification codes - Continued

For models TS4000 E & TS4000 EFS in projecting arm (Figure 1), parallel arm (Figure 6) and transom mount (Figure 61) applications to EN1154:



For models TS4000 E & TS4000 EFS in projecting arm (Figure 1) & transom mount (Figure 61) to EN1155:



For model TS4000EN 5-7 in projecting arm (Figure 1) & transom mount (Figure 61) applications:

4 8 7 5	1	1	4
---------	---	---	---

Note: power ratings shall be appropriate to the leaf sizes subject to a minimum size 3 (as specified in BS EN 1154).

Further Information

Further information regarding the details contained in this data sheet may be obtained from GEZE GmbH (Tel: 01543 443024).

Further information regarding the CERTIFIRE certification and other approved products can be obtained from CERTIFIRE (Tel: 01925 646777).

Signed J/078 & C/007

ful ligg-

Page 7 of 7

Issued: 1st Ma Revised: 11th D Valid to: 30th M

1st May 1997 11th December 2023 30th May 2028